

VOC Content Test Certificate

Wednesday April 18th, 2007

Supplier: Regupol

Unit 1, 5 Cary Grove

Minto NSW 2566

Sample Description: Regupol one part solvent free polyurethane acoustic adhesive

Production Date: March 2007

Date Tested: April 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star IEQ-13	Regupol one part solvent free polyurethane acoustic adhesive
Wood Flooring Adhesive 100 grams per Litre	2 grams per Litre



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant