

VOC Content Test Certificate

Friday, April 26th 2013

Supplier: Regupol (Australia) Pty Ltd (155 Smeaton Grange Rd, Smeaton Grange, NSW, 2567)

Sample Description: Regupol One Part Multi-Use Flooring Adhesive

Date Tested: Sept 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">Regupol One Part Multi-Use Flooring Adhesive</p>
<p>Rubber Flooring Adhesive</p> <p>60 grams per Litre as VOC content per material</p>	<p>45 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV130429