

VOC Content Test Certificate

Friday, 23rd January 2015

Supplier: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC 3137)

Sample Description: Regupol Resilient One Part Adhesive

Date Tested: October 2007 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Regupol Resilient One Part Adhesive
Carpet adhesive 50 grams per Litre as VOC content per material	11 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

F0710-21a